


QuARC 2025 Experiments: Scintillator Sheet Response Comparisons

**Joe Bateman, Sonia Escribano Rodriguez, Harry Barnett,
Connor Godden, Matt Warren, Febian, Simon Jolly**

University College London

- QuARC Detector Upgraded in 2025
 - New scintillator sheets (modules contained mix of transparent machined sheets, translucent sheets and injection moulded transparent sheets)
 - Updated electronics to reduce noise and have dual-sided readout of sheets.
- 3 beam tests in 2025
 - Prague PTC in April 2025 (1 morning) – 4 modules
 - UCLH in May 2025 (1 day) – 4 modules
 - Trento Proton Therapy Centre (2 nights of QuARC measurements) – 3 modules







- Module 1:
 - Front of module: mostly sanded translucent sheets
 - Back of module: intertwined translucent sanded sheets, and machined polished sheets (combo of thick and thin)
- Module 2 (best module):
 - All machined polished sheets and those closest to 3mm (i.e. between 2.99mm and 3.01mm)




- Module 3:
 - All sanded translucent sheets (all under 3mm: 2.96 – 2.99 mm thicknesses)
- Module 4:
 - Prague experiment:
 - Front half – combination of injection moulded sheets and transparent polished sheets
 - Back half: combination of injection moulded and translucent sanded sheets
 - Irregularity of injection moulded sheets meant stack was too large for holder and difficult to assemble hence PD's did not align well to sheets.
 - UCLH experiment:
 - Combination of sanded sheets and polished sheets (only a few near the front)

QuARC Module Side View





$$coefficient[i] = \frac{ST_{back}[i] + ST_{front}[i]}{2}$$



245 MeV (*Varian*) or
228 MeV (*IBA*), back


245 MeV (*Varian*) or
228 MeV (*IBA*), front

- IBA Machine so 228 MeV is max energy.
- Two shoot through measurements performed per module (1 in each orientation).
- Shoot-through irradiations performed at clinical current – 8 nA.
- To note in next set of slides – A-side electronics more reliable – the less reliable PDs and boards were put on B-side



Different scintillator sheets, so light output differs.
 Much higher light output on machined polished sheets (number 400 onwards)

Right-hand side: Run002_a






MODULE 1: compare STFront and STBack




A side (right) sees more light with STBack and B side (left) side sees more light with STFront -> Always more light when the board is placed on the left hand side of the beam.

A side



B side



Transparent machined polished sheets




MODULE 2: compare STFront and STBack




- A side (right) sees more light with STBack and B side (left) side sees more light with STFront again -> Always more light when the board is placed on the left hand side of the beam.
- More uniform overall response due to all sheets being machined transparent sheets

A side

Run006



B side






MODULE 3: compare STFront and STBack




- Older sanded translucent sheets are showing much larger variation in response despite being all the same 'type' of sheet.

A side



B side






MODULE 4: compare STFront and STBack



- Machined and polished sheets (MP) showed greatest light output
- Injection moulded (IM) sheets showed better light output than sanded translucent sheets (S)


A side

Run014



B side

Run014






Bragg Peak results

120 MeV


Run030_a (E = 119.85MeV, R0 = 106.24mm)



140

MeV


Run031_a (E = 140.00MeV, R0 = 139.28mm)






Bragg Peak results II

Run033_a ($E = 100.05\text{MeV}$, $R0 = 77.57\text{mm}$)



Run035_a ($E = 79.99\text{MeV}$, $R0 = 52.53\text{mm}$)



- Measurements with 4 modules (4th module different Prague measurements and consists of mostly sanded sheets and a couple polished sheets but no injection moulded).
- 2 shoot throughs per module (front and back) - approx 10,000 MU was sufficient for 30,000 measurements
- Pristine Bragg peak measurements across entire clinical range (70 – 245 MeV) and SOBPs





Side A Shoot through comparisons

17



PD Charge (pC)



UCLH 20250524 Side A (Uncalibrated)

Module 1

Module 2

Module 3

Module 4



Photodiode Number



Side B Shoot through comparisons

18



PD Charge (pC)


UCLH 20250524 Side B (Uncalibrated)

Module 1

Module 2

Module 3

Module 4



PhotoSlide Number




Side A Calibrated

19



Normalised PD Charge (a.u.)


UCLH 20250524 Side A (Calibrated)






Side B Calibrated

Normalised PD Charge (a.u.)




Side A



Range: 45.54 mm, Energy: 73.69 MeV

Side B




Range: 45.65 mm, Energy: 73.79 MeV




150 MeV – BP in Mod 2

Side A




Range: 156.59 mm, Energy: 149.73 MeV

Side B




Range: 156.82 mm, Energy: 149.86 MeV

Side A



Side B






245 MeV – BP in Mod 4

24




Side A



Range: 360.17 mm, Energy: 241.54 MeV

Side B



Range: 361.29 mm, Energy: 241.97 MeV



UCLH SOBP Reconstruction

25



SOBP Statistics


Plateau (90% level): 109.545 mm
to 172.58 mm

Plateau width: 63.035 mm


Plateau mean : 4.68837 a.u.

Plateau std dev: 0.129093 a.u.

Flatness: 2.75347%




- 3 nights of measurements in the research room at Trento PTC
 - Night 1: QuARC
 - Calibrations and **Bragg Peak measurements** scaling current up to FLASH (briefly).
 - Night 2: Combined QuARC + SciFi:
 - Dynamic range testing (fibres at low gain)
 - Beam position measurements
 - Night 3: SciFi Measurements
 - Dynamic range testing (fibres at high gain)
 - Different spot sizes (varying energy)



- Measurements with 3 modules (to allow for fibre detector inside case).
- 2 shoot throughs for each module at 10 nA ion source current (~ 1.5 nA nozzle current).
- Current scan performed on front shoot throughs of module 1 in both CONV and FLASH mode.
- Response linearity current scan to measure linearity of detector response.
- Beam position measurements to correlate QuARC dual-sided position measurement with fibre array position measurement by moving detector in 5mm increments horizontally.




Side A Shoot through comparisons






Side B Shoot through comparisons





Side A Calibrated





Side B Calibrated




Module 1

Module 2

Module 3

Normalised PD Charge (a.u.)

TIFPA 20250929 Side B (Calibrated)






Module 1: ST Front


32




TIFPA 20250929 Run008 (Uncalibrated)



TIFPA 20250929 Run009 (Uncalibrated)



TIFPA 20250929 Run010 (Uncalibrated)



No log file data
from Trento from
these runs so
nozzle current
based on PBT wiki
notes

Note that only
polished sheets
appear to saturate




Module 1: ST Front

33




TIFPA 20250929 Run011 (Uncalibrated)



FSR 12.5 pC

TIFPA 20250929 Run012 (Uncalibrated)



FSR 350 pC




Summed the charge from

a) Sanded sheets

b) Polished sheets

Evident from previous plots that the polished sheets have much higher light output, here it can be seen they have steeper response also.

Lack of accurate nozzle current data from Trento is reason for data at start looking odd.







Response Linearity

Response linearity of entire QuARC detector by summing the average PD values across the measurement time.

179 MeV



148 MeV






179 MeV 20 nA




Side A




$kB = 0.105512$
 $\text{Sigma}_0 = 3.11298$

Side B




$kB = 7.32185e-06$
 $\text{Sigma}_0 = 3.03636$

Side A




$E_0 = 178.18 \text{ MeV}$
 $kB = 0.10059$

Side B



$E_0 = 178.03 \text{ MeV}$
 $kB = 0.01$


Side A



$$E_0 = 178.18 \text{ MeV}$$

$$kB = 0.0995859$$


Side B




$$E_0 = 177.9 \text{ MeV}$$

$$kB = 1.87366e-05$$


A




B



A




B




Note how the sanded sheets in module 1 respond when the beam is scanned – due to large calibration factor being less reliable for these sheets

A




B




Note how the sanded sheets in module 1 respond when the beam is scanned – due to large calibration factor being less reliable for these sheets


TIFPA 20250929 Run036 (Uncalibrated)




TIFPA 20250929 Run036 (Calibrated)



TIFPA 20250929 Run034 (Uncalibrated)



TIFPA 20250929 Run034 (Calibrated)






- To summarise this effect:
- Poor light output on module 3 sheets (sanded sheets) and slight misalignment of beam in calibration.
- Hence large calibration factors on module 3 sheets with large uncertainties.
- This leads to over exaggeration of peak on percentage depth light (PDL) curve and hence appears as lower kB when it isn't.
- Effect isn't present when Bragg peak is in module 2 (where there are good sheets) – so isn't explicitly a position effect.
- Similar effect also causes sanded sheets in module 1 to fluctuate when beam position is being scanned.



Position Scan - reconstructed 148 MeV Bragg Curves




Reconstructed Bragg Curves - TIFPA 20250930 Run037



Beam 20mm to left

A: $R_0 = 151.47$ mm, $E_0 = 146.91$ MeV
B: $R_0 = 151.51$ mm, $E_0 = 146.93$ MeV
Avg: $R_0 = 151.49$ mm, $E_0 = 146.92$ MeV


Reconstructed Bragg Curves - TIFPA 20250930 Run028



Beam in centre

A: $R_0 = 151.29$ mm, $E_0 = 146.81$ MeV
B: $R_0 = 151.51$ mm, $E_0 = 146.93$ MeV
Avg: $R_0 = 151.4$ mm, $E_0 = 146.87$ MeV

Reconstructed Bragg Curves - TIFPA 20250930 Run032



Beam 20mm to right

A: $R_0 = 151.46$ mm, $E_0 = 146.9$ MeV
B: $R_0 = 151.73$ mm, $E_0 = 147.05$ MeV
Avg: $R_0 = 151.595$ mm, $E_0 = 146.975$ MeV

Consistent range reconstruction across entire range of beam spot positions.







QuARC Δ/Σ & Fibre μ Measurements



$$\text{shift}[i] = \frac{PD_A[i] - PD_B[i]}{PD_A[i] + PD_B[i]}$$

Calibrated





QuARC + Fibre Position Measurements

